

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low-Relaxation, Seven-Wire Steel Strand for Prestressed Concrete

(Details as per the attached Scope of Certification)

manufactured by:

THE SIAM INDUSTRIAL WIRE CO. LTD.

160 Moo 11, T. Nonglalo, A. Bankhai, Rayong 21120, Thailand

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM A 416/A 416M:17a

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

ARIF AL MARZOOQI

for/ Certification and Quality Control of Products Section Manager
Dubai Central Laboratory Department-Dubai Municipality



Certificate No: CL08020080
Valid Until: 15/08/2024



Current Issue Date: 16/08/2023
Original Issue Date: 27/11/2008



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

OPEN-DATA

DM-DCLD-F-IC-2031 Rev 22

DUBAI CENTRAL LABORATORY DEPARTMENT

DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL08020080

Certificate Issued To: **THE SIAM INDUSTRIAL WIRE CO. LTD.**
160 Moo 11, T. Nonglalo, A. Bankhai,
Rayong 21120, Thailand.

Applicable Standard Specification: **ASTM A 416/A 416M:17a** Standard
Specification for Low-Relaxation, Seven-Wire
Steel Strand for Prestressed Concrete

Applicable Specific Rules: **DM-DCLD-RD-DP21-2131 (IC)** "Specific Rules
for Certification of Low-Relaxation, Seven-Wire
Steel Strand for Prestressed Concrete (as per
ASTM A 416/A 416 M –17a) Through Factory
Assessment".

NO.	PRODUCT DESCRIPTION	Nominal Diameter (mm)	PRODUCT DETAILS
1	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	9.53	Seven-Wire Low relaxation steel strand , Grade 270[1860] with nominal diameter 9.53mm, minimum Breaking Strength of 102 kN.
2	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	12.7	Seven-Wire Low relaxation steel strand ,Grade 270[1860] with nominal diameter 12.7mm, minimum Breaking Strength of 184 kN.
3	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	15.2	Seven-Wire Low relaxation steel strand , Grade 270[1860] with nominal diameter 15.2 mm, minimum Breaking Strength of 261 kN.
4	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	15.7	Seven-Wire Low relaxation steel strand, Grade 270[1860] with nominal diameter 15.7mm, minimum Breaking Strength of 279 kN.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCLD-CQPS PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL08020080

Remarks:

NOTE1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE2: The above product shall bear the DCL Conformity Mark (applied on each product or on the packaging).

Original Issue Date : 27 November 2008

Current Issue Date : 16 August 2023

Valid Until : 15 August 2024



ARIF AL MARZOOQI

for **MANAGER**

CERTIFICATION AND QUALITY CONTROL OF PRODUCTS SECTION